



**Americans with Disabilities Act  
ADA CHECKLIST FOR POLLING PLACES  
Polling Place Accessibility Checklist – Modified**

---

Location Address: **RAYMOND HIGH SCHOOL**  
**45 Harriman Hill Road, Raymond NH 03077**

Requesting Entity: **Todd Ledoux, Raymond School District**

Date: **March 15, 2017** Time: **8:00 am**

Evaluator: **Colleen Durkin-Blackburn, Accessibility Specialist**

---

This checklist is designed to provide guidance for determining whether a polling place has basic accessibility features needed by voters with disabilities.

For each question below there are citations to the 2010 ADA Standards for Accessible Design (2010 Standards). Please review the 2010 Standards for all requirements.

There are some differences between the 1991 ADA Standards for Accessible Design (1991 Standards) and the 2010 Standards. Elements and spaces in a building constructed or altered before March 15, 2012, that complied with the 1991 Standards may remain in compliance with the 2010 Standards. See 28 C.F.R. §35.150(b)(2) for more information.

The Governor's Commission on Disability offers information and resources and does not provide legal advice, legal opinions, or enforcement. All provided information and comments are non-binding, and should be considered as suggestions.

**Status of Polling Place:**

- All Elements Compliant
- Non-Compliant Elements Remediable with Temporary Measures
- Non-Compliant Elements Not Remediable with Temporary Measures

**PARKING** Only complete this section if off-street parking, parking lot, or parking structure is provided to voters. If off-street parking or a parking lot or structure is not provided to voters, go to Section B.

A	If more than 25 parking spaces are provided to voters, see the 2010 Standards for the number of accessible parking spaces required. (§208.2)	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	N/A <input type="checkbox"/>	<b>Comments/Remedies</b> <i>45 spaces, 2 accessible spaces provided.</i>
A1	Is there at least one designated van accessible space with signage with the International Symbol of Accessibility and designated "van accessible"? (§§208.2, 208.2.4, 502.6)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<i>Two van-accessible spaces are provided. Signage is provided, however is considered non-compliant due to its removability and portability.</i>
A2	Are the designated van accessible spaces at least 96" wide with a 96" wide access aisle, or 132" wide with a 60" wide access aisle? (§§502.2, 502.3) Width of space <u>96"</u> Width of access aisle <u>156"</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<i>Compliant</i>
A3	For van accessible spaces (particularly in a garage or parking structure), is there vertical clearance of at least 98" for the vehicular route to the parking space, in the parking space and access aisle, and along the vehicular route to the exit? (§502.5)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<i>Compliant</i>
A4	Are designated accessible parking spaces and the access aisles serving them on a level surface, with slopes not exceeding 1:48 in all directions? (Note: Curb ramps may not be part of an access aisle since they include slopes greater than 1:48.) (§502.4)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<i>Compliant</i>
A5	Are the surfaces of the designated accessible parking spaces and access aisles stable, firm, and slip resistant? (§§502.4, 302.1)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<i>Compliant</i>
A6	Are the designated accessible parking spaces located on the shortest accessible route to the accessible entrance? (§208.3.1)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<i>Compliant.</i>

**PASSENGER DROP OFF AREA** Only complete this section if a passenger drop-off area is provided for voters. If a drop-off area is not provided to voters, go to Section C.

B		Yes	No	N/A	Comments/Remedies
B1	Is the vehicle pull-up space on a level surface, with slopes not exceeding 1:48 in all directions? (§503.4)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Compliant.
B2	Is the access aisle next to the vehicle pull-up space on a level surface, with a slope not exceeding 1:48 in all directions? (§503.4)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Compliant.
B3	Is there vertical clearance of at least 114" (9 feet 6 inches) from the site entrance to the vehicle pull-up area, in the access aisle, and along the vehicular route to the exit? (§503.5)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Compliant.
B4	Is a curb ramp provided if a curb separates the access aisle from the accessible route to the accessible entrance? (§§206.2.1, 503.3)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
B5	Is the width of the curb ramp surface at least 36" (not counting the side flares)? (§405.5)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
B6	Does an accessible route connect the access aisle and curb ramp to the accessible entrance of the polling place? (§206.2)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Compliant.

**EXTERIOR ROUTE TO ACCESSIBLE ENTRANCE** Complete a separate Exterior Route form, when applicable, for the routes from 1) parking, 2) passenger drop-off areas, 3) public sidewalks and 4) public transportation stops.

C	1 of 4 PARKING to ENTRANCE	Yes	No	N/A	Comments/Remedies
C1	Is the route at least 36" wide? (§403.5.1)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Compliant.
C2	Is the route free of abrupt changes in level greater than 1/2", including stairs? (§303.3)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Compliant.
C3	Is the route free of surface openings greater than 1/2", such as grates or holes in the pavement? (§302.3)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Concrete pad at entrance contains wear and tear with a surface opening greater than 1/2".
C4	Are walking surfaces stable, firm, and slip resistant? (§302.1)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Concrete pad at entrance contains wear and tear with a surface opening greater than 1/2".
C5	Is the route free of wall mounted objects that protrude more than 4" into the path of travel and are between 27" and 80" high? (§307.2)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Compliant.
C6	Is the route free of post mounted objects that protrude more than 12" into the path of travel and are between 27" and 80" high? (§307.3)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Compliant.
C7	Are objects that hang over the pedestrian route 80" or higher, including the underside of exterior stairs? (§307.4)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
C8	Is the cross slope of the accessible route no greater than 1:48? (§§403.3, 405.3)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Compliant
C9	If the route crosses a curb, is there a curb ramp that is at least 36" wide with a slope no more than 1:12? (§§303.4, 405.2, 405.5, 406.1)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
C10	Is the running slope of part of the route greater than 1:20? If yes, go to Section G. (§402.2)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Compliant
C11	Is the cross slope of the accessible route no greater than 1:48? (§§403.3, 405.3)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Compliant

**EXTERIOR ROUTE TO ACCESSIBLE ENTRANCE** Complete a separate Exterior Route form, when applicable, for the routes from 1) parking, 2) passenger drop-off areas, 3) public sidewalks and 4) public transportation stops.

C	2 of 4 PASSENGER DROP-OFF to ENTRANCE	Yes	No	N/A	Comments/Remedies
C1	Is the route at least 36" wide? (§403.5.1)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Compliant.
C2	Is the route free of abrupt changes in level greater than 1/2", including stairs? (§303.3)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Compliant.
C3	Is the route free of surface openings greater than 1/2", such as grates or holes in the pavement? (§302.3)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Concrete pad at entrance contains wear and tear with a surface opening greater than 1/2".
C4	Are walking surfaces stable, firm, and slip resistant? (§302.1)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Concrete pad at entrance contains wear and tear with a surface opening greater than 1/2".
C5	Is the route free of wall mounted objects that protrude more than 4" into the path of travel and are between 27" and 80" high? (§307.2)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Compliant.
C6	Is the route free of post mounted objects that protrude more than 12" into the path of travel and are between 27" and 80" high? (§307.3)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Compliant.
C7	Are objects that hang over the pedestrian route 80" or higher, including the underside of exterior stairs? (§307.4)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
C8	Is the cross slope of the accessible route no greater than 1:48? (§§403.3, 405.3)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Compliant.
C9	If the route crosses a curb, is there a curb ramp that is at least 36" wide with a slope no more than 1:12? (§§303.4, 405.2, 405.5, 406.1)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
C10	Is the running slope of part of the route greater than 1:20? If yes, go to Section G. (§402.2)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Compliant.
C11	Is the cross slope of the accessible route no greater than 1:48? (§§403.3, 405.3)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Compliant.

**EXTERIOR ROUTE TO ACCESSIBLE ENTRANCE** Complete a separate Exterior Route form, when applicable, for the routes from 1) parking, 2) passenger drop-off areas, 3) public sidewalks and 4) public transportation stops.

C	3 of 4 SIDEWALK to ENTRANCE	Yes	No	N/A	Comments/Remedies
C1	Is the route at least 36" wide? (§403.5.1)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	No sidewalks present.
C2	Is the route free of abrupt changes in level greater than 1/2", including stairs? (§303.3)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
C3	Is the route free of surface openings greater than 1/2", such as grates or holes in the pavement? (§302.3)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
C4	Are walking surfaces stable, firm, and slip resistant? (§302.1)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
C5	Is the route free of wall mounted objects that protrude more than 4" into the path of travel and are between 27" and 80" high? (§307.2)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
C6	Is the route free of post mounted objects that protrude more than 12" into the path of travel and are between 27" and 80" high? (§307.3)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
C7	Are objects that hang over the pedestrian route 80" or higher, including the underside of exterior stairs? (§307.4)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
C8	Is the cross slope of the accessible route no greater than 1:48? (§§403.3, 405.3)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
C9	If the route crosses a curb, is there a curb ramp that is at least 36" wide with a slope no more than 1:12? (§§303.4, 405.2, 405.5, 406.1)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
C10	Is the running slope of part of the route greater than 1:20? If yes, go to Section G. (§402.2)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
C11	Is the cross slope of the accessible route no greater than 1:48? (§§403.3, 405.3)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A

**EXTERIOR ROUTE TO ACCESSIBLE ENTRANCE** Complete a separate Exterior Route form, when applicable, for the routes from 1) parking, 2) passenger drop-off areas, 3) public sidewalks and 4) public transportation stops.

C	4 of 4: PUBLIC TRANSPORTATION to ENTRANCE	Yes	No	N/A	Comments/Remedies
C1	Is the route at least 36" wide? (§403.5.1)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
C2	Is the route free of abrupt changes in level greater than 1/2", including stairs? (§303.3)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
C3	Is the route free of surface openings greater than 1/2", such as grates or holes in the pavement? (§302.3)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
C4	Are walking surfaces stable, firm, and slip resistant? (§302.1)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
C5	Is the route free of wall mounted objects that protrude more than 4" into the path of travel and are between 27" and 80" high? (§307.2)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
C6	Is the route free of post mounted objects that protrude more than 12" into the path of travel and are between 27" and 80" high? (§307.3)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
C7	Are objects that hang over the pedestrian route 80" or higher, including the underside of exterior stairs? (§307.4)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
C8	Is the cross slope of the accessible route no greater than 1:48? (§§403.3, 405.3)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
C9	If the route crosses a curb, is there a curb ramp that is at least 36" wide with a slope no more than 1:12? (§§303.4, 405.2, 405.5, 406.1)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
C10	Is the running slope of part of the route greater than 1:20? If yes, go to Section G. (§402.2)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
C11	Is the cross slope of the accessible route no greater than 1:48? (§§403.3, 405.3)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A

**POLLING PLACE ENTRANCES**

D		Yes	No	N/A	Comments/Remedies
D1	Is the clear width of the door opening (one door or one active leaf of a double door) at least 32"? (§404.2.3)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	32" measured.
D2	Is each door hardware useable with one hand without tight grasping, pinching, or twisting of the wrist? (§§309.4, 404.2.7)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Compliant.
D3	On the pull side of the door, is there at least 18" of clearance provided to the side of the latch? (§404.2.4)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Compliant.
D4	Is the area in front of the door level, with slopes no greater than 1:48 in all directions? (§405.7.1)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Compliant.
D5	If there are doors in a series, is the distance between the two hinged doors at least 48" plus the width of the door swinging into the space? (§404.2.6)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Compliant.
D6	Can the second door (interior door) in the series be opened with no more than 5 pounds of force? (§309.4)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	9# of force measured at interior door.
D7	Does the second door (interior door) in the series comply with D2, D3, and D4, above?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	9# of force measured at interior door.
D8	Are door thresholds no higher than 1/2"? (Note: If the threshold is between 1/4" and 1/2" it must be beveled.) (§404.2.5)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Compliant.
D9	Do inaccessible entrances have signage directing voters to the accessible entrance? (§216.6)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	No permanent signage observed.
D10	If voters are directed to an alternative accessible entrance, is this entrance kept unlocked during voting hours? (28 C.F.R. §§35.130,	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Per verbal representation by Mr. Ledoux.



**ROUTE FROM ENTRANCE INTO VOTING AREA**

E		Yes	No	N/A	Comments/Remedies
E1	Is the route at least 36" wide? (§403.5.1)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Compliant.
E2	Is the route free of wall mounted objects that protrude more than 4" into the path of travel and are between 27" and 80" high? (§307.2)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Compliant.
E3	Is the route free of post mounted objects that protrude more than 12" into the path of travel and are between 27" and 80" high? (§307.3)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Compliant.
E4	Are objects that hang over the route 80" or higher, including the underside of stairs? (§307.4)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Compliant.
E5	Is the route free of abrupt changes in level greater than 1/2", including stairs? (§303.3)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Compliant.
E6	Is the running slope of part of the route greater than 1:20? If yes, go to Section G. (§ 303.4)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
E7	If the route to the voting area has stairs, is a platform lift or elevator provided? If yes, go to Section H (lifts) or Section I (elevators). (§402.2)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
E8	If doors are provided along the route to the voting area, is the clear width of each door opening (one door or one active leaf of a double door) at least 32"? (§404.2.3)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Per representation by Mr. Ledoux, doors propped open during voting hours.
E9	Is each door hardware useable with one hand without tight grasping, pinching, or twisting of the wrist? (§§309.4, 404.2.7)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Compliant.
E10	Can each door be opened with no more than 5 pounds of force? (§309.4)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Compliant.
E11	Is the threshold at each door no higher than 1/2"? (Note: If the threshold is between 1/4"	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Compliant.

E11	Is the threshold at each door no higher than 1/2"? (Note: If the threshold is between 1/4" and 1/2" it must be beveled.) (§404.2.5)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<i>Compliant.</i>
E12	On the pull side of each door, is there at least 18" of clearance provided to the side of the latch? (§404.2.4)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<i>Compliant.</i>
E13	Is the area in front of each door level, with slopes no greater than 1:48 in all directions? (§§404.2.4.4, 405.7.1)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<i>Compliant.</i>

**WITHIN VOTING AREA**

F		Yes	No	N/A	Comments/Remedies
F1	Are floor surfaces stable, firm, and slip resistant? (§302.1)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<i>Glossy wood flooring. Slip resistant observed during dry conditions. Stable and firm throughout.</i>
F2	Is the route free of wall mounted objects that protrude more than 4" into the path of travel and are between 27" and 80" high? (§307.2)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<i>Compliant.</i>
F3	Is the route free of post mounted objects that protrude more than 12" into the path of travel and are between 27" and 80" high? (§307.3)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<i>Compliant.</i>
F4	Are objects that hang over the route 80" or higher, including the underside of stairs? (§307.4)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<i>Compliant.</i>
F5	Is there enough room to provide a route at least 36" wide to the registration table and voting stations? (§403.5.1)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<i>Compliant.</i>
F6	Is there enough room to provide a turning space in front of at least one voting station, such as a circle that is at least 60" in diameter? (§304.3)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<i>Compliant.</i>
F7	Is there enough room to provide a turning space in front of at least one accessible voting machine, such as a circle that is at least 60" in diameter? (§304.3)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<i>Compliant.</i>

**RAMPS:** 1 of 0 Complete a separate ramp form for each ramp, whether exterior or interior.

G	Location: N/A – no ramp within the polling site.	Yes	No	N/A	Comments/Remedies
G1	Is the running slope of the ramp no greater than 1:12? (§405.2)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
G2	Is the cross slope of the ramp 1:48 or less? (§405.3)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
G3	Is the rise (height) for any ramp run 30" or less? (§405.6)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
G4	Is the ramp, measured between handrails, at least 36" wide? (§405.5)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
G5	Does the ramp have a level landing that is at least 60" long, at the top and bottom of each ramp section? (§405.7)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
G6	For every 30" of rise, is a level landing at least 60" long provided? (§§405.6, 405.7)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
G7	Is a level landing, at least 60" by 60" provided where the ramp changes direction? (§405.7.4)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
G8	If the rise of the ramp is greater than 6", are handrails provided that are between 34" and 38" above the ramp surface? (§§405.8, 505.4)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
G9	If the rise of the ramp is greater than 6" and the ramp or landing has a vertical drop-off on either side of the ramp, is edge protection provided? (§405.9)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A

**RAMPS: 2 of 0**

G	Location: N/A – no ramp within the polling site.	Yes	No	N/A	Comments/Remedies
G1	Is the running slope of the ramp no greater than 1:12? (§405.2)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
G2	Is the cross slope of the ramp 1:48 or less? (§405.3)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
G3	Is the rise (height) for any ramp run 30" or less? (§405.6)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
G4	Is the ramp, measured between handrails, at least 36" wide? (§405.5)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
G5	Does the ramp have a level landing that is at least 60" long, at the top and bottom of each ramp section? (§405.7)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
G6	For every 30" of rise, is a level landing at least 60" long provided? (§§405.6, 405.7)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
G7	Is a level landing, at least 60" by 60" provided where the ramp changes direction? (§405.7.4)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
G8	If the rise of the ramp is greater than 6", are handrails provided that are between 34" and 38" above the ramp surface? (§§405.8, 505.4)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
G9	If the rise of the ramp is greater than 6" and the ramp or landing has a vertical drop-off on either side of the ramp, is edge protection provided? (§405.9)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A

**LIFTS**

H	Location: N/A – no lift within polling areas.	Yes	No	N/A	Comments/Remedies
H1	Is the lift operational at the time of the survey? (28 C.F.R. §§35.130, 35.133)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
H2	Is the lift independently operable, or can it be made so during Election Day? (§410.1)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
H3	Is there 30" by 48" of clear floor space within the lift? (§§410.3, 305.3)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
H4	Are the controls for the lift no higher than 48"? (§§410.5, 309.3, 308)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
H5	Are the controls useable with one hand without tight grasping, pinching or twisting? (§§410.5, 309.4)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
H6	Is the clear width of the door opening/gate opening at the end of the lift at least 32"? If a side door/gate is provided, is the clear opening width at least 42"? (§410.6)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A

**ELEVATORS**

I	Location: N/A – no elevator within polling area.	Yes	No	N/A	Comments/Remedies
I1	Is the elevator car door opening at least 36" wide? (§407.3.6, Table 407.4.1)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
I2	Is there space to maneuver within the elevator car, e.g., 51" deep and 68" wide; OR 80" deep and 54" wide; OR 60" deep and 60" wide? (§407.4.1)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
I3	Are hallway elevator call buttons 48" high or lower? (§§407.2.1.1, 308.2, 308.3)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
I4	Are elevator car controls 48" high or lower? (§§407.4.6.1, 308.2, 308.3)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
I5	Does the elevator have visible and audible signals in the hallway to indicate the arrival and direction of the elevator car? (§407.2.2.1)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
I6	Does the elevator have visible and audible signals within the elevator car to indicate the position of the car? (§407.4.8)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A

**COMMENTS**

*Please refer to the enclosed written report.*